



सत्यमेव जयते

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR
FIRE AND EMERGENCY SERVICES, ASSAM
PANBAZAR, GUWAHATI



Form - G

UBIN : 616/227916/AABTR6671F/12/2023

UAIN : FNESBNOCI/2023/02435

NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN APPLICATION FOR FIRE NOC FOR ONE STORIED / MULTI-STORIED / HIGH RISE BUILDING UNDER ASSAM FIRE SERVICE RULE 1989 (FORM NO I)

Hazard Category: **Low Hazard**

This NOC is issued to **Rajagiri Christ Academy** on **07/01/2024** with reference to Compliance Report No. **NIL** dated **30/12/2023**

I here by certify that the building as per description below at **Dag No. 6,7,8 Patta No. 9 Mouza Madhya Baska Place Subankhata , BAKSA** has been inspected in respect of implementation of inbuilt Fire Fighting, Fire Prevention and Means of escape measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has no objection in its occupation/ utilization for the purpose of:

DETAILS OF APPROVED OCCUPATION

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	841.25 SQM	SCHOOL
2.	FIRST FLOOR	841.25 SQM	SCHOOL
3.	SECOND FLOOR	841.25 SQM	SCHOOL

THIS NOC IS VALID UP TO 6/1/2027

Place of issue : **GUWAHATI**

Date of issue : **07/01/2024**

CONDITIONS :

(Subject to Conditions mentioned here under)

Director of Fire and Emergency
Services,
Guwahati, Assam

Manager
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam

Principal
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam

in the existing arrangements.

3. The fire fighting equipments should be in serviceable condition at all time
4. Water reservoir should always be kept full up to brim
5. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
6. The NOC is liable to be cancelled if the premises (for which the NOC is granted) when inspected are not found conforming to the description and condition under which this NOC is granted.

Director of Fire and Emergency
Services,
Guwahati, Assam



Note : This certificate is computer generated and does not require any Seal/Signature.


Manager
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam


Principal
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam