



GOVT. OF ASSAM

OFFICE OF THE JOINT DIRECTOR OF HEALTH SERVICES::BAKSA

DISTRICT CENTRE::MUSHALPUR::BTAD::ASSAM::781372

E-mail: - jtdhs.baksa.mushalpur@gmail.com



No. JDHS/BKS/H&H/2025-26/ 3440 /Dated Mushalpur, the 20th November, 2025.

To Whom It May Concern

Health & Hygiene Certificate

This is to certify that, as per report submitted by the SDM &HO, Mushalpur BPHC (Ref. No. MBPHC/Misc//2025/187 Dated: 20-11-2025), the school premises of **Rajagiri Christ Academy** located at **Bizgaon, Subankhata** under **Baksa** district has provision of safe drinking water, Separate toilets for Boys' & Girls' with running water, well maintained drainage system and the Health & hygiene of the school campus is satisfactory.

THIS CERTIFICATE IS VALID UPTO 19-11-2026


Manager
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam


Joint Director of Health Services
Baksa, Mushalpur, BTAD
Joint Director of Health Services
Baksa - Mushalpur
BTAD : Assam


Principal
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam



GOVT. OF ASSAM

OFFICE OF THE JOINT DIRECTOR OF HEALTH SERVICES::BAKSA

DISTRICT CENTRE::MUSHALPUR::BTAD::ASSAM::781372

E-mail: - jtdhs.baksa.mushalpur@gmail.com



No. JDHS/BKS/H&H/2025-26/ 3440 /Dated Mushalpur, the 20th November, 2025.

To,

The Principal
Rajagiri Christ Academy, Bizgaon, Subankhata

Sub: - Forwarding of **Health & Hygiene Certificate**.

Sir,

With reference to the subject cited above, I have the honour to forward herewith the **Health & Hygiene Certificate** in respect of your school.

This is for favour of your kind information and necessary action.


Joint Director of Health Services
Baksa, Mushalpur, BTAD
Joint Director of Health Services
Baksa - Mushalpur
BTAD : Assam


Manager
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam


Principal
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam

	DISTRICT LEVEL LABORATORY, MUSHALPUR					
	OFFICE OF THE ASSTT. EXECUTIVE ENGINEER(PHE)					
	MUSHALPUR SUB-DIVISION, MUSHALPUR, BAKSA, ASSAM					
	Email:- www.dlmmushalpur@gmail.com					
U/LR no. TC-1081825000000218F				Humidity= 65%		
Temperature during Analysis= 25.3° C						
Test Report						
Test Report No:- 645461				Issue Date:- 01/11/2025		
Issued To:- Rajagiri Christ Academy						
Customer Reference No:- 1811				Sample ID No. 1811		
Sample Description: Drinking Water				Sample Type: Boring		
Village:- Bizagaon				Block: Dhamdhama		
Sample location:- Rajagiri Christ Academy				Sample collected by:		
Sample collected on dated:- 27/10/2025				Sample is not collected by the Laboratory.		
Sample received on dated:- 27/10/2025				Sample Quantity : 1000ml Non Acidified.		
Date of Analysis Started :- 29/10/2025				Date of Analysis completed:- 30/10/2025		
Results						
Sr. No.	Parameter	Protocol	Results	IS:10500:2012 (Second		Unit
				Requirement (Acceptable Limit)	Permissible Limit in the absence of alternate	
1	pH at 25 °C	IS 3025: Part 11 :	7.55	6.5 to 8.5	No relaxation	
2	Turbidity	IS 3025: Part 10 :	0.0	1	5	NTU
3	Total Alkalinity	IS 3025: Part 23 :	80	200	600	mg /l.
4	Chloride	IS 3025: Part 32 :	8	250	1000	mg /l.
5	Total Hardness	IS 3025: Part 21 :	185.40	200	600	mg /l.
6	Fluoride	APHA 4500- F D : 24th EDTN 2023	0.08	1	1.5	mg /l.
7	Arsenic	IS 3025: Part 37 :	BDL	0.01	No relaxation	mg /l.
8	Sulphate	IS 3025: Part 24 :	7.46	200	400	mg /l.
9	Nitrate	IS 3025: Part 34 :	1.21	45	No relaxation	mg /l.
10	Iron	APHA 3500- Fe B : 24th EDTN 2023	0.17	1	No relaxation	mg /l.
11	Calcium	IS 3025: Part 40 : 2023	52.86	75	200	mg /l.
12	Magnesium	APHA 3500- Mg-B : 24th EDTN 2023	13.02	30	100	mg /l.
13	Total Dissolved solids (TDS)	IS 3025: Part 16 : 2023	242	500	2000	mg /l.
14	Colour	IS 3025: Part 4 : 2021	-	5	15	Hazen
15	Taste	IS 3025: Part 8 : 2023	-	Agreeable	Agreeable	
16	Odour	IS 3025: Part 6 : 2022	-	Agreeable	Agreeable	

Remarks:- BDL: Below Detection Limit

Notes:

1. The test report and result relate to the sample of the material of received and tested in the laboratory.
2. The test report cannot be regenerated/ reproduced in whole or in part without written permission of this laboratory.
3. The test report cannot be used for publicity or any legal purpose.
4. The sample meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.

Reviewed By

Quality Manager
(Bhanumati Goyari)
DLL Mushalpur (PHE)

Authorized By

Quality Manager
(Rohan Mustafa Gohain)
Mushalpur Sub-Division (PHE)

.....END OF TEST REPORT.....

Manager
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam

Principal
RAJAGIRI CHRIST ACADEMY
Subankhata, Pin - 781372
BTAD, Baksa, Assam

	DISTRICT LEVEL LABORATORY, MUSHALPUR OFFICE OF THE ASST. EXECUTIVE ENGINEER(PHE) MUSHALPUR SUB DIVISION, MUSHALPUR, BAKSA, ASSAM Email: www.dlhmushalpur@gmail.com					
	IIR No. TC 1081825000000217F					
	Temperature during Analysis = 25 °C					
Test Report						
Test Report No - 645305			Issue Date - 01/11/2025			
Issued To - Rajagiri Christ Academy						
Customer Reference No - 1810			Sample ID No - 1810			
Sample Description - Drinking Water			Sample Type - Aqua			
Village - Bizagaon			Block - Dhamdhama			
Sample location - Rajagiri Christ Academy			Sample collected by			
Sample collected on dated - 27/10/2025			Sample is not collected by the Laboratory			
Sample received on dated - 27/10/2025						
Sample Quantity - 1000ml Non Acidified,						
Date of Analysis Started - 29/10/2025			Date of Analysis completed - 30/10/2025			
Results						
Sr. No.	Parameter	Protocol	Results	IS:10500:2012 (Second)		Unit
				Requirement (Acceptable Limit)	Permissible Limit in the absence of alternate	
1	pH at 25 °C	IS 3025: Part 11 :	9.01	6.5 to 8.5	No relaxation	
2	Turbidity	IS 3025: Part 10 :	0.0	1	5	NTU
3	Total Alkalinity	IS 3025: Part 23 :	50	200	600	mg /L
4	Chloride	IS 3025: Part 32 :	7.5	250	1000	mg /L
5	Total Hardness	IS 3025: Part 21 :	45.32	200	600	mg /L
6	Fluoride	APHA 4500- F D : 24th EDTN 2023	0.10	1	1.5	mg /l
7	Arsenic	IS 3025: Part 37 :	BDL	0.01	No relaxation	mg /l
8	Sulphate	IS 3025: Part 24 :	6.17	200	400	mg /l
9	Nitrate	IS 3025: Part 34 :	2.03	45	No relaxation	mg /l
10	Iron	APHA 3500- Fe B : 24th EDTN 2023	0.18	1	No relaxation	mg /L
11	Calcium	IS 3025: Part 40 : 2023	9.09	75	200	mg /l
12	Magnesium	APHA 3500- Mg-B : 24th EDTN 2023	5.50	30	100	mg /l
13	Total Dissolved solids (TDS)	IS 3025: Part 16 : 2023	106	500	2000	mg /l
14	Colour	IS 3025: Part 4 : 2021	-	5	15	Hazen
15	Taste	IS 3025: Part 8 : 2023	-	Agreeable	Agreeable	
16	Odour	IS 3025: Part 6 : 2022	-	Agreeable	Agreeable	

Remarks:- BDL: Below Detection Limit

Notes:

1. The test report and result relate to the sample of the material of received and tested in the laboratory.
2. The test report cannot be regenerated/ reproduced in whole or in part without written permission of this laboratory.
3. The test report cannot be used for publicity or any legal purpose.
4. The sample meant for chemical analysis will be disposed off after 15 days from the date of issue of test report.

Reviewed By


 Quality Manager
 (Bhanumati Goyari)
 DLL Mushalpur (PHE)

Authorized By


 Quality Manager
 (Bhanumati Goyari)
 DLL Mushalpur (PHE)

.....END OF TEST REPORT.....


 Manager
 RAJAGIRI CHRIST ACADEMY
 Subankhata, Pin - 781372
 BTAD, Baksa, Assam


 Principal
 RAJAGIRI CHRIST ACADEMY
 Subankhata, Pin - 781372
 BTAD, Baksa, Assam